



RIVERHEAD WATER DISTRICT

**** ADDENDUM No. 1 **
SEPTEMBER 22, 2016**

Project No.: RDWD 16-02
Project Name: INSTALLATION OF NEW VARIABLE FREQUENCY DRIVES AT PLANT NO. 10
SOUND SHORE ROAD, RIVERHEAD
Bid Due Date: THURSDAY, SEPTEMBER 27, 2016 AT 2:05 PM
Description: ADDITION TO CONTRACT

ADDITIONS:

Please note the following during preparation of bid proposals:

1. Furnish and install a new output and bypass contactor that are factory aligned, mechanically and electrically interlocked.
2. Furnish and install a new line reactor in the existing MCC cubicle.

Contractor shall review revised Sheet E1.0 dated 09.19.2016 for a detailed scope of work required.

=====

This addendum forms a part of the contract documents and modifies the original bidding documents. A copy of this signed addendum shall be included with the bid proposal. Contractor shall also verify receipt of this addendum with engineer for the District. Send verification of receipt to jcollins@h2m.com.

Name: _____
(Please Print)

Signature: _____

Company: _____

Date: _____