

Appendix P



RIVERHEAD SEWER DISTRICT
Town of Riverhead
200 Howell Avenue
Riverhead, New York 11901

October 18, 2007

Suffolk County Dept. of
Health Services
Center Drive
Riverhead, NY 11901

Re: Property Located:
Riverhead, NY 11901
Tax Map # 600-101-1-3 & 600-119-1-6

Please be advised that the above referenced property is located within the boundaries of the Riverhead Sewer District. Plans, with a last revision date of October 17, 2007, have been received and approved by the Riverhead Sewer District. Sewer connection is available to service this parcel.

Should you have any questions or require any additional information, please feel free to contact me at (631) 727-3069.

Very truly yours,

Michael Reichel, Superintendent
Riverhead Sewer District

cc: Building Department

RWD

Riverhead Water District, 1035 Pulaski Street, Riverhead, N.Y., 11901
(631) 727-3205 Fax: (631) 369-4608

DATE: March 20, 2007

SUBJECT: Availability of public water to RIVERHEAD PROPERTIES.

**LOCATION: SUFFOLK COUNTY TAX MAP # 0600-101-1-lot 3 and #0600-119-1-lot 6.
Location: North side of Old Country Road (C./R. 58), Riverhead, N.Y., 11901
TOWN OF RIVERHEAD**

**ATTENTION: E. S. Kalogeras, Union Square, 727 Union Avenue, Aquebogue, NY, 11931;
Telephone #: 631-722-4040; FAX #: 631-722-4004**

Dear Mr. Kalogeras,

Property located at SUFFOLK COUNTY TAX MAP # 0600-101-1-Lot 3 AND #0600-119-1-lot 6 are currently within the boundaries of the Riverhead Water District and can be served by same. Please take note that this property maybe subject to the Riverhead Water District's Developmental Fees.

If I can be of further service please do not hesitate to contact me.

Sincerely Yours,



Gary J. Pendzick
Superintendent
Riverhead Water District

E. S. KALOGERAS, P.E.
Consulting Engineer



UNION SQUARE

707 UNION AVENUE

RIVERHEAD, NY 11901

February 16, 2007

Mr. Gary Pendzick, Supt.
Riverhead Water District
200 Howell Avenue
Riverhead, New York 11901

Re: Water Availability for The Shops at Riverhead,
SCTM# 600-101-01-03 & 600-119-01-06

Dear Gary:


We are presently in the preliminary design stage of the above referenced project. Enclosed please find a preliminary water and sewer layout plan of the site, for your use. We respectfully request a "Letter of Water Availability" be sent to us, for inclusion into the project's Draft Environmental Impact Statement and for submission to the Health Department.

As you can see, we are planning for dual 12-inch connections at your SC Route 58 facilities for the project through two (2) meters and RPZs. The meters and RPZs may be constructed in utility rooms within Buildings "M" and "N", respectively, rather than in above ground, bermed, pits.

We assume that your system is capable of supplying an average day domestic demand plus irrigation demand of 50,000 gpd for the future retail center plus a 1,500 gpm fire flow rate. Please provide static pressures and any available fire flow data, that we can anticipate at the project.

Your quick response and cooperation on this matter will be appreciated.


Very truly yours,
E.S. KALOGERAS, P.E.
CONSULTING ENGINEER



E.S. Kalogeras, P.E.

Encl. (Preliminary Site Utilities Plan)
ESK:wpwin12.0

E. S. KALOGERAS
Consulting Engineer



100 N. WASHINGTON SQUARE

707 UNION AVENUE

RIVERHEAD, NY 11901

February 16, 2007

Mr. Michael Reichel, Supt.
Riverhead Sewer District
200 Howell Avenue
Riverhead, New York 11901

Re: Sewer Availability for The Shops at Riverhead,
SCTM# 600-101-01-03 & 600-119-01-06

Dear Mike:


We are presently in the preliminary design stage of the above referenced project. Enclosed please find a preliminary water and sewer layout plan of the site, for your use. We respectfully request a "Letter of Sewer Availability" be sent to us, for inclusion into the project's Draft Environmental Impact Statement and for submission to the Health Department.

As you can see, we are planning for a gravity sewer system to collect sewage from each building at the retail center and collecting it at a below grade pumping station. Pumping station will be designed to current Health Department standards and have a backup generator set to insure operation at all times. Our sewage will be pumped via a force main to your connection at the north side of S.C. Route 58, which we understand was installed at the time of your Sewer District extension. Please advise us of your requirements for connection and the exact location of the connection.

We assume that your system is capable of receiving an average day sewage flow of 25,360 gpd for the future retail center. The flow also includes two (2) restaurants whose kitchen flow will be intercepted by grease traps prior to transporting kitchen waste to the on-site pump station. Grease traps will be designed to County Health standards.

Your quick response and cooperation on this matter will be appreciated.

Very truly yours,
E.S. KALOGERAS, P.E.
CONSULTING ENGINEER



E.S. Kalogeras, P.E.

Encl. (Preliminary Site Utilities Plan)
ESK:wpwin12.0